



Government Of West Bengal  
Office Of The Director General  
West Bengal Fire & Emergency Services  
13D, Mirza Ghalib Street, Kolkata - 16

Memo no.:IND/WB/FES/20182019/42331

Date: 05-11-2022

From:  
Divisional Fire Officer  
Fire Prevention Wing,  
West Bengal Fire & Emergency Services

To: LAKSHMIPAT SINGHANIA ACADEMY  
12-B, ALIPORE ROAD, KOLKATA - 700027

Sub: Renewal of Fire safety Certificate for an existing G + VIII storied school building under group occupancy Educational Building in the name & style "LAKSHMIPAT SINGHANIA ACADEMY" at the premises no 12-B, ALIPORE ROAD, KOLKATA - 700027

This is in reference to your application no. 0125191228700536 dated 21-06-2022 regarding the Renewal of Fire safety Certificate for an existing G + VIII storied school building under group occupancy Educational Building in the name & style "LAKSHMIPAT SINGHANIA ACADEMY" at the premises no 12-B, ALIPORE ROAD, KOLKATA - 700027

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

**Recommendation:**

1. Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Driveway.
2. The interior finish decoration of the building shall be made with low flame spread material confirming to the I.S. Specification.
3. To eliminate risk of fire hazards, good house-keeping both for inside and outside of the building shall be strictly maintained.
4. Existing Electrical wiring of the whole building shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling and ducts.
5. Periodical flashing of water in the Hydrants Pipe line shall be made to maintain the efficiency working performance of the

The authenticity of this document can be verified by accessing the URL: [edistrict.wb.gov.in](http://edistrict.wb.gov.in) and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number: 0125191228700536.

Page : 1

Powered By For secure paperless solutions  
Please visit [www.emsigner.com](http://www.emsigner.com)



*Misra*

installed FFPS.

6.The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all venerable of the building.

7.The employees and security staffs shall be conversant with installed Fire Fighting Equipment of the building and to operate in the event of Fire and Testing.

8.Mock Fire practice and Evacuation Drill shall be performed periodically with participants of all the occupants of the building.

9.Transformer (if any) and switch gear room protection system to be maintained in proper manner & record keeping to be maintained in the fire prevention maintenance register.

10.Electrical ducts shall be sealed vertically and horizontally at each floor level by fire resisting materials.

11.Unauthorized cooking arrangement in any floor of the building using L.P.G., Kerosene etc. shall not be permitted and Fire License shall have to be obtained for storing and processing with L.P.G. and other highly combustible articles.

12.First-Aid Fire Fighting system shall be provided as per I.S. specification.

13.Arrangement shall have to be made for regular checking, testing and maintenance of all the firefighting installation in the building to keep them in perfectly good working condition at all the times.

14.If required the old lines shall have to be replaced with new lines, the cable shall always be laid in M.S. conduit pipes continuously bonded with the earth.

15.The Fire Safety Audit & Electric Audit to be conducted a regular interval and to be recorded in the fire prevention maintenance register.

This Fire Safety Certificate is valid for 3 (Three) year from the date of issue of this letter and have to be renewed within validity period & a certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services for performance of all the Fire & Life Safety arrangement installations of the building.

Signature Not Verified  
Digitally signed by NIHAR  
RANJAN ROY  
Date: 2022.11.06 20:44:19 IST

Divisional Fire Officer  
West Bengal Fire & Emergency Services



*J. Minerva*

**FIRE SAFETY CERTIFICATE**

No. IND/WB/FES/20182019/42331

Dated: 05.11.2022

Certified that LAKSHMIPAT SINGHANIA ACADEMY at (12-B ALIPORE ROAD, KOLKATA 700 027 comprised of G + 8 FLOORS (upper floors) owned/occupied by LAKSHMIPAT SINGHANIA ACADEMY have complied with the fire prevention and fire safety requirements in accordance with rule of State/UT Fire Service Rules, and verified by the officers concerned of Fire Service on 05.11.2022 (date of inspection) in the presence of Mr. Nihar Ranjan Roy. Divisional Fire Officer, Fire Prevention Wing, West Bengal Fire & Emergency Services (name and addresses of the Manager/Secretary or his representative) and that the building/premises is fit for occupancy upto classes XII (X/XII) with effect from 05.11.2022 for a period of 3 years in accordance with rule and subject to compliance of specific conditions as appended:

1. Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Driveway.
2. The interior finish decoration of the building shall be made with low flame spread material confirming to the I.S. Specification.
3. To eliminate risk of fire hazards, good house-keeping both for inside and outside of the building shall be strictly maintained.
4. Existing Electrical wiring of the whole building shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling and ducts.
5. Periodical flashing of water in the Hydrants pipe line shall be made to maintain the efficiency working performance of the installed FFFs.

Issued on 05.11.2022 at 20:44:19 by Mr. Nihar Ranjan Roy

\*Strike out whichever is not applicable.

**Fire & Security Products & Services**  
**Partha Sarathi Dhar.**  
**Authorised Signatory**

Signature with Seal: \_\_\_\_\_

Name: PARTHA SARATHI DHAR.

Designation: AUTHORISED SIGNATORY.

Name & Address of Department/Office: \_\_\_\_\_

To

Address:- 30A, MOHENDRA ROY  
 LANE  
 KOLKATA - 700 046.

\_\_\_\_\_  
 (Name & Address of the Institution)

**ENDORSEMENT**

The No Objection Certificate issued by Fire Service stand cancelled an annulled due to

\_\_\_\_\_  
 (reasons to be recorded).

\_\_\_\_\_  
 (Name and designation of the authorized signatory)